




BUSBAR LOCATION	BUSBAR RATING (MAIN)	CABLE ENTRY OUTGOING	FAULT LEVEL	FINISH
BUSBAR RATING	CABLE ACCESS	DEGREE OF PROTECTION	FAULT LEVEL (DROPPERS)	SEGREGATION
BUSBAR RATING (DROPPERS)	CABLE ENTRY INCOMING	EARTH BAR LOCATION	FAULT LEVEL (MAIN)	SUPPLY

1	800A TPN MCCB MAINS INCOMER
1A	800A TPN MCCB NON-AUTO MAINS INCOMER
2	800A TPN MCCB STANDBY GENERATOR INCOMER
3	800A TPN MCCB MOBILE GENERATOR INCOMER
4	800A TPN NON-AUTO MCCB GENERATOR AUTO-CHANGEOVER
5	800A TPN NON-AUTO MCCB MAINS AUTO-CHANGEOVER
6	800A TP 3-POSITION BYPASS SWITCH
7	AUTO-CHANGEOVER CONTROLS AND INSTRUMENTATION
8	AUTO-CHANGEOVER MCB'S
9	800A TPN NON-AUTO MCCB LOAD-OUTPUT SWITCH
10	800A TPN MCCB DISASTER RECOVERY INCOMER
11	400A TPN MCCB FUTURE PFC



This drawing is confidential and may not be used, copied or disclosed to anyone without permission of GR ELECTRICAL SERVICES LTD	ISSUE	MODIFICATION	NAME	DATE

Title

Drawn by	G. R. ELECTRICAL SERVICES LIMITED
Date	SHERBURN (01977) 681681
Checked by	FAX (01977) 685605
Date	PROJECT No.
SCALE	DRAWING No.

